



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131545, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:301, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Tuesday, September 03, 2013

Corrective Action Required
1 MISC

NEC 380-10; 410-56(f) / IRC E3901.10; E3902.6 SECURING OF ELECTRICAL RECEPTACLES / SWITCHES: SOME NOT TIGHT TO BOX; CHECK ALL AND ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE.

Corrective Action Required
2 MISC

NEC 370-20; IRC E3806.5-6 SET-BACK OF ELECTRICAL RECEPTACLE / SWITCH BOXES: MUST BE FLUSH WITH COMBUSTIBLE WALL SURFACE. SEE AT BREAK ROOM

In-wall Inspection	Khanh Nguyen	Passed	Tuesday, September 03, 2013
---------------------------	--------------	--------	-----------------------------

In-wall Inspection	John Borns	Passed	Tuesday, September 03, 2013
---------------------------	------------	--------	-----------------------------

Comments: