

Temporary Certificate of Occupancy

Permit #: PRCOM20122641
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063
Inspected On: Wednesday, September 04, 2013
Inspected By: John Borns
Expiration Date: 9/12/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, September 04, 2013

Corrective Action Required:

1	MISC	RESOLVE WATER UTILITIES ISSUE ON TIMETABLE AGREED-UPON WITH LSWU
---	------	--

Corrective Action Required:

4	MISC	ISSUES WITH ELECTRICAL RECEPTACLES: - RECEPTACLE @ S PANEL NOT SOLID TO WALL - RECEPTACLE @ SERVING COUNTER SOUTH END DISPLAYS HOT/NEUTRAL REVERSE
---	------	---

Corrective Action Required:

7	MISC	SAFETY INSPECTION AT ROOF SUBJECT TO APPROVAL.
---	------	--

Corrective Action Required:

8	MISC	COMPLETE SUPPORT OF PVC ELECT CONDUIT AT S EAVE OF BLDG
---	------	---

Corrective Action Required:

9	MISC	NEC 330.30: NON-METALLIC ELECTRICAL WHIP NOT SECURED TO
---	------	---

STRUCTURE WITHIN 12" OF ENTRY TO A/C DISCONNECT
ENCLOSURE.