



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131754, Building Permit - Commercial
Address: 310 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|--------------|----------|----------------------------|
| Above Ceiling Inspection | Mark Harding | Failed | Friday, September 06, 2013 |

Corrective Action Required
1 MISC

OPEN BOX FRONT WALL, INSTALL TIE SUPPORT WIRES ON 2X4
LIGHT, CONNECT HEAT DUCT
OK TO SET TILE BUT NEED TO SEE CORECTIONS

Comments: