

Temporary Certificate of Occupancy

Permit #: PRCOM20131173
Address: 1900 NE LANGSFORD RD, LEES SUMMIT, MO 64086
Inspected On: Friday, September 06, 2013
Inspected By: Khanh NguyenJoe DirKhanh NguyenJoe Dir
Expiration Date: 10/4/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, September 06, 2013

Corrective Action Required:

1	MISC	-CLOSE OPEN ELECTRICAL BOX ABOVE CEILING -PROVIDE MAXIMUM 15 AMP BREAKERS FOR MC CONDENSER UNITS CIRCUIT PROTECTION -RESTROOMS NOT COMPLETED
---	------	---

*TCO APPROVED FOR MEDICAL CLINIC USE

Occupancy Inspection - Fire	Joe Dir	Passed	Friday, September 06, 2013
------------------------------------	---------	--------	----------------------------