



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20130943, Building Permit - Residential
Address: 2050 SW COUNTY LINE RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Friday, September 06, 2013

Corrective Action Required
1 MISC

- 4. FIRESTOP MSTR TUB, SOLID BLOCK REAR 2ST FLOOR
CHASE BACK WALL.FIRESTOP LANDING FROM WALL,
- 9. INSTALL DBL JOIST BSMT AS PER PLANS
- 13. GARAGE DOOR STRAPS 3rd CAR

Comments: