



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

September 10, 2013

DACUR INVESTMENT COMPANY INC
2700 KENDALLWOOD PKWY # 208
GLADSTONE, MO 64119

Permit No: PRCOM20131937
Project Title: CARESPOT EXPRESS HEALTHCARE
Project Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081
Parcel Number: 62140031600000000
Location: SUMMIT SHOPPING CENTER LOT 1
Type of Work: NEW TENANT FINISH
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR NEW URGENT CARE FACILITY TREATING ILLNESS,
LACERATIONS, BROKEN BONES ETC.

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Rejected

1. 2006 IPC 403.2 - Separate facilities. Where plumbing fixtures are required, separate facilities shall be provided for each sex. (See code for possible exceptions.)

Action required - Please label one of the restrooms as men's and one as women's.

2. 2006 IBC 1011.1 - Where required. Exits and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel. Access to exits shall be marked by readily visible exit signs in cases where the exit or the path of egress travel is not immediately visible to the occupants. Exit sign placement shall be such that no point in a corridor is more than 100 feet or the listed viewing distance for the sign, whichever is less, from the nearest visible exit sign.

Action required - Provide exit signage in corridors 112 and 123 towards the rear of the space providing direction to door 110.

Fire Plan Review

Reviewed By: Brian Austerman

Approved

1. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In

Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

Provide addressing, verified at inspection

2. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of a 2A10B:C extinguisher for every 3,000 sq/ft or for every 75' of travel distance. Verified at inspection

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.