



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130393, Building Permit - Commercial
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Thursday, September 12, 2013

Partial Correction
1 MISC

OK TO POUR WHEN READY CONCRETE GRADE BEAM +
INTEGRAL COLUMN FOOTINGS

Partial Correction
2 MISC

OK TO POUR WHEN READY ISOLATED COLUMN FOOTINGS AT:
C/2; **TWO F4 CANOPY FOOTINGS OK TO POUR AFTER RE-BAR IS
CHAIR-UP FOR 3" CLEARANCE FROM BOTTOM OF
EXCAVATION**

Comments: