



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130203, Building Permit - Commercial
Address: 1800 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Mark Harding	Failed	Monday, September 16, 2013

Corrective Action Required
1 MISC

1. FINAL GRADE, SOD, EROSION CONTROL.
2. FINAL ELECTRICAL INSPECTION REQUIRED AFTER POWER IS ESTABLISHED.
3. APPROVAL FROM PLANNING DEPARTMENT.--
4. APPROVAL FROM FIRE DEPARTMENT- APPROVED
5. BOND NUETRAL BUS IN PANEL
6. INSTALL HOLD DOWN DEVISE AT MAIN 100 AMP BREAKER. RECALL WHEN ITEMS ARE COMPLETE

Occupancy Inspection - Fire	Joe Dir	Passed	Monday, September 16, 2013
------------------------------------	---------	--------	----------------------------

Corrective Action Required
1 MISC

mount one 2A-10BC rated fire extinguisher on a a wall close to an exit with the top of the extinguisher no higher than 60" off finished floor.

Final Building Inspection - Commercial	Mark Harding	Failed	Monday, September 16, 2013
---	--------------	--------	----------------------------

Corrective Action Required

1 MISC

1. FINAL GRADE, SOD, EROSION CONTROL.
 2. FINAL ELECTRICAL INSPECTION REQUIRED AFTER POWER IS ESTABLISHED.
 3. APPROVAL FROM PLANNING DEPARTMENT.--
 4. APPROVAL FROM FIRE DEPARTMENT- APPROVED
 5. BOND NUETRAL BUS IN PANEL
 6. INSTALL HOLD DOWN DEVISE AT MAIN 100 AMP BREAKER.
- RECALL WHEN ITEMS ARE COMPLETE

Comments: