



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130203, Building Permit - Commercial  
Address: 1800 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	Mark Harding	Failed	Tuesday, September 17, 2013

Corrective Action Required  
1 MISC

1. FINAL GRADE, SOD, EROSION CONTROL.
2. FINAL ELECTRICAL INSPECTION REQUIRED AFTER POWER IS ESTABLISHED.
6. INSTALL HOLD DOWN DEVISE AT MAIN 100 AMP BREAKER.--  
NO HOLD DOWN INSTALLED

**Comments:**