



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20122702, Building Permit - Commercial  
Address: 308 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

| Inspection:  | Inspector: | Outcome: | Date:                       |
|--|------------|----------|-----------------------------|
| <b>Occupancy<br/>Inspection - Codes<br/>Commercial</b> | John Borns | Failed   | Tuesday, September 17, 2013 |

Corrective Action Required  
2 MISC

RESOLVE ANY PLANNING & DEVELOPMENT DEPARTMENT  
ISSUES

Corrective Action Required  
5 MISC

NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT  
PANEL(S): EACH BREAKER POSITION MUST BE LABELED. MUST  
BE LEGIBLE, SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER  
POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO  
MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE  
POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE"

Corrective Action Required  
6 MISC

LABEL EXTERIOR OF ELECT PANELS BY UNIT #. ALSO,  
BLANK-OFF ANY UNUSED BREAKER POSITION OPENINGS.

**Comments:**