



**LEE'S SUMMIT**  
MISSOURI



**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No: PRCOM20130305 Date: September 17, 2013  
Project Title: LEE'S SUMMIT POLICE Applicant: CONLEY SPRINKLER INC.  
DEPARTMENT HEADQUARTERS 822 MAIN ST  
Location: PLEASANTON, KS 66075  
10 NE TUDOR RD,  
LEES SUMMIT, MO 64086 Primary: (913) 768-7385  
Type of Work:  
Occupancy Group: MIX  
Description: POLICE DEPARTMENT  
ADDITION AND RENOVATION - OCCUPANCY  
TYPES ARE A-2, I-3 AND S-2  
Construction Type: Type IIB (Unprotected)  
Map Page: 195B

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Brian Austerman**

**Released for Construction**

1. 2006 IFC 510.1- Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed and readily visible.

Control valves and drains shall be marked if not visible

2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing

3. If exits have been extended that had previously had a standpipe at that exit, the standpipe shall be extended to the new exit

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**