



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131173, Building Permit - Commercial
Address: 1900 NE LANGSFORD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, September 20, 2013

Corrective Action Required
1 MISC

- INSTALL RESTROOM SIGNAGE ON THE WALL @ THE LATCH SIDE OF DOOR
- COMPLETE PARTITION ON MAN RESTROOM. URINAL PARTITION SHALL BE NO MORE THAN 12" ABOVE THE FLOOR AND EXTEND 5 FT UP
- PLUG HOLES IN DOORS

*TCO APPROVED FOR MEDICAL CLINIC USE

Comments: