



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20132019, Building Permit - Commercial  
Address: 226 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Failed	Friday, September 20, 2013

Corrective Action Required  
1 MISC

NEC 250.92B; IRC E3510.1. BONDING OF SERVICE ENCLOSURES & EQUIPMENT: NIPPLES ENTERING THROUGH REMAINING KNOCKOUTS REQUIRE BONDING BUSHINGS WITH BONDING JUMPERS TERMINATED AT ENCLOSURE HOUSINGS. LOCKNUT NOT SUFFICIENT FOR BONDING.

Corrective Action Required  
2 MISC

ELECTRICAL SERVICE ADDRESS IDENTIFICATION: NOT FOUND AFFIXED AT METER / DISCONNECT

**Comments:**