



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132057, Building Permit - Commercial
Address: 202 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Commercial	John Borns	Passed	Monday, September 23, 2013
Final Plumbing Inspection - Commercial	John Borns	Passed	Monday, September 23, 2013

Comments: OK TO COVER WHEN READY. CLOSE PERMIT.