



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131638, Building Permit - Commercial  
Address: 840 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Not Ready	Tuesday, September 24, 2013

Corrective Action Required  
1 MISC

ABOVE-CEILING ELECTRICAL WORK NOT COMPLETED;  
LIGHTING FIXTURES NOT INSTALLED PER DRAWING.

**Comments:**