



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20130710, Building Permit - Residential
Address: 1629 NE SHADOW VALLEY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, September 25, 2013

Corrective Action Required
1 MISC

-RAFTERS ABOVE MASTER AREA-REDUCE SPAN TO 14'4"
-SUPPORT RIDGE ABOVE BED ADJACENT TO LAUNDRY TO
BEARING WALL

PLUMBING:
-SHALL PROTECT THE 1" WARDFLEX INSIDE A STRIPWOUND
CONDUIT. DO NOT SECURE TO STUD

****OK TO INSULATE. DO NOT ROCK**

Gas Service Inspection - Residential	Khanh Nguyen	Failed	Wednesday, September 25, 2013
---	--------------	--------	-------------------------------

Corrective Action Required
1 MISC

-SEE ALLROUGH INSPECTION

Comments: