

Temporary Certificate of Occupancy

Permit #: PRCOM20130027
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Unit: 120, LEES SUMMIT, MO 64086
Inspected On: Wednesday, September 25, 2013
Inspected By: John Borns
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Wednesday, September 25, 2013

Corrective Action Required:

1 MISC RESOLVE FIRE DEPARTMENT ISSUES

Partial Correction:

2 MISC UROLOGY DEPARTMENT AREA OK FOR OCCUPANCY

ONCOLOGY/RADIATION DEPARTMENT AREA OK TO SET UP FOR BUSINESS. NO PATIENTS PRIOR TO APPROVAL.

ALL EMERGENCY CIRCUITS MUST BE TESTED ON GENERATOR POWER AND CERTIFIED OPERATIONAL.

TCO EXTENDED 9/25/13 TO ACCOMMODATE COMPLETION OF SITEWORK AT BUNKER AREA.

