



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20131924, Building Permit - Residential
Address: 1741 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|------------------------------|
| Electrical Service Inspection - Residential | John Borns | Failed | Thursday, September 26, 2013 |

Corrective Action Required
1 MISC

GROUND ROD FOUND WITH G.E.C. TERMINATED, BUT G.E.C. NOT TERMINATED WITHIN ENCLOSURE.

Corrective Action Required
2 MISC

ELECTRICAL SERVICE ADDRESS IDENTIFICATION AT METER / DISCONNECT NOT FOUND AFFIXED TO ENCLOSURE

| | | | |
|--|------------|--------|------------------------------|
| Final Electrical Inspection - Residential | John Borns | Failed | Thursday, September 26, 2013 |
|--|------------|--------|------------------------------|

Comments: