



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130766, Building Permit - Commercial
Address: 1820 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Thursday, September 26, 2013
Above Ceiling Inspection	John Borns	Passed	Thursday, September 26, 2013

Comments: NO ISSUES FOUND ON PERMIT SCOPE OF WORK. CLOSE PERMIT.