

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20130791, Building Permit - Commercial

Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground John Borns Partial Thursday, September 26, 2013

Electrical Inspection

- Commercial

Partial Correction

1 MISC OK TO COVER WHEN READY ONE 3" PVC UNDERGROUND

CONDUIT FROM EAST RETAINING WALL TO NEW LOCATION OF

LIGHTING CONTROLLER

Partial Correction

2 MISC OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT

FOLLOWING LOCATIONS: L.P.#4; 5; 10; 11; 15; 21; 25; THREE LPCB's ALONG EAST SIDE OF RETAINING WALL; 1;2;3;6;7;8;9; 12;

13; 14;

Partial Correction

3 MISC OK TO COVER WHEN READY CONDUIT AND ENCLOSURES FOR

SEVEN LUMINAIRES AT THE FOOT OF THE WEST FACE OF THE

RETAINING WALL.

Partial Correction

4 MISC OK TO COVER WHEN READY PVC CONDUIT TO & IN THE AREAS

OF L.P.#4; 5; 10; 11; 15; 21; 25; THREE LPCB's ALONG EAST SIDE

OF RETAINING WALL; 12-TO-13-TO-14; 6-TO-8-TO-9; 7-TO-9;

1-TO-2-TO-3-TO-4; [FROM 16 TO 17 TO 18 TO 19 TO 20;

Comments: