



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130449, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, Unit:530, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Thursday, September 26, 2013

Corrective Action Required

1	MISC	ANSI 603.3 MOUNTING OF MIRRORS AT ACCESSIBLE RESTROOMS: SET BOTTOM OF VIEWING SURFACE <= 40" AFF
---	------	---

Corrective Action Required

2	MISC	IBC 2406; IRC R308.4 GLAZING IN HAZARDOUS LOCATIONS: NOT FOUND TO BE ETCHED AS SAFETY GLAZED
---	------	---

Corrective Action Required

3	MISC	ELECTRICAL FEED SOURCE(S) TO BE APPROVED BEFORE OCCUPANCY
---	------	--

Corrective Action Required

4	MISC	RESOLVE ANY FIRE DEPARTMENT ISSUES
---	------	------------------------------------

Corrective Action Required

5	MISC	<b>OCCUPANCY STATUS: OK TO SET UP FOR BUSINESS. NO PATIENTS PRIOR TO APPROVAL.</b>
---	------	--

<b>Occupancy Inspection - Fire</b>	Joe Dir	Temporary C of O	Thursday, September 26, 2013
--	---------	------------------	------------------------------

Corrective Action Required

1	MISC	- address all doors from the corridor leading into the suite - suite needs generator test - air handler shut-down test
---	------	--

**Comments:**