



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131998, Building Permit - Commercial
Address: 1125 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Passed	Friday, September 27, 2013

In-wall Inspection	Khanh Nguyen	Failed	Friday, September 27, 2013
---------------------------	--------------	--------	----------------------------

Corrective Action Required

1	MISC	-PROTECT PVC WHERE INSTALLED WITHIN 1.5" OF NAILING SURFACE AT STUD AND BOTTOM WALL PLATE -INSTALL BLOCKINGS FOR GRAB BARS
---	------	---

Comments: