



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Monday, September 30, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY LIGHT GAUGE FRAMING @
PARAPET WALLS AT: **PERIMETER AT ELEVATION 132'-8" AND
130'-8"; LOWER WALL 132'-10" AT CLEARSTORY;**

Comments: