



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130791, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Monday, September 30, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY ONE 3" PVC UNDERGROUND CONDUIT FROM EAST RETAINING WALL TO NEW LOCATION OF LIGHTING CONTROLLER

Partial Correction
2 MISC

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: L.P.#4; 5; 10; 11; 15; 21; 25; THREE LPCB's ALONG EAST SIDE OF RETAINING WALL; 1;2;3;6;7;8;9; 12; 13; 14; [16; 17; 18; 19; 20;

Partial Correction
3 MISC

OK TO COVER WHEN READY CONDUIT AND ENCLOSURES FOR SEVEN LUMINAIRES AT THE FOOT OF THE WEST FACE OF THE RETAINING WALL.

Partial Correction
4 MISC

OK TO COVER WHEN READY PVC CONDUIT TO & IN THE AREAS OF L.P.#4; 5; 10; 11; 15; 21; 25; THREE LPCB's ALONG EAST SIDE OF RETAINING WALL; 12-TO-13-TO-14; 6-TO-8-TO-9; 7-TO-9; 1-TO-2-TO-3-TO-4; FROM (22) ONE 1" + ONE 2" EAST TO FEEDER PANEL NEAR (21); 24 TO 29; 22TO 26 TO 29; IRRIGATION SLEEVE + 1" UNDER DRIVE BETWEEN 27 & 28; **FROM 29 TO 28 TO CONNECT TO RUN FROM 27; 23 TO 24**

Comments: