



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131231, Building Permit - Commercial
Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, October 04, 2013

Corrective Action Required
1 MISC

UNDERSLAB/GROUND ELECTRICAL OK BELOW:
-SERVICE CONDUITS TO MDP AND SUBPANEL
-SECONDARY TO SERVICE EQUIPMENT

-CIRCUIT TO SUMP PUMP
-CIRCUITS TO LIGHT POLES OF: WEST PARKING LOT,
NORTHEAST PARKING LOT, LIGHT POLES AT FRONT

Comments: