



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20130393	Date:	October 07, 2013
Project Title:	FREDDY'S STEAKBURGERS	Applicant:	ALLIANCE FIRE PROTECTION LLC
Location:	194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081		130 WEST 9TH AVE NORTH KANSAS CITY, 64116
Type of Work:		Primary:	(913) 888-0647
Occupancy Group:	A-2		
Description:	RESTAURANT		
Construction Type:	Type VB (Unprotected)		
Map Page:	195E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Plans show FDC as single 2 1/2 connection. FDC shall be a single 4" Storts type, verified at inspection and testing
2. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.