

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX: 816-969-1201

## **Inspection Summary**

Permit #: PRCOM20131998, Building Permit - Commercial Address: 1125 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Tuesday, October 08, 2013
Corrective Action Required			
1 MISC	-CIRCUIT TO RTU: 1)EXPOSED NM TYPE CABLE IN ABOVE-CEILING SPACE IS NOT ALLOWED. 2) SHALL SUPPORT THIS CIRCUIT PER CODE -NM SHALL BE SUPPORTED PER 330.30. NO MORE THAN 6 FT FROM POINTS OF SUPPORT. -SHALL NOT USE THE CEILING SUPPORTING WIRES TO SUPPORT ELECTRICAL RACEWAYS OR CABLES. INSTALL INDEPENDENT SUPPORTING WIRINGS FOR THESE RACEWAYS & CABLES. ALL ENCLOSURES SUPPORTED BY THE CEILING WIRES SHALL BE TIGHT (NO SLACK)		

Comments: