



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20131998	Date:	October 08, 2013
Project Title:	9 ROUND FITNESS	Applicant:	ALLIANCE FIRE PROTECTION LLC
Location:	1125 NE RICE RD, LEES SUMMIT, MO 64086		130 WEST 9TH AVE NORTH KANSAS CITY, 64116
Type of Work:			
Occupancy Group:	B	Primary:	(913) 888-0647
Description:	TENANT FINISH FOR GYM		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195D		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. NFPA 2002 ed. Chapter 13.8.6.3.3 Minimum distances from Walls. Sprinklers shall be located a minimum of 4 in. (102 mm) from a wall.

For information only, verified at inspection

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.