

Temporary Certificate of Occupancy

Permit #: PRCOM20130449
Address: 110 NE SAINT LUKES BLVD, Unit:530, LEES SUMMIT, MO 64086
Inspected On: Thursday, October 10, 2013
Inspected By: John BornsJohn Borns
Expiration Date: 10/24/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, October 10, 2013

Corrective Action Required:
2 MISC IBC 2406; IRC R308.4 GLAZING IN HAZARDOUS LOCATIONS: NOT FOUND TO BE ETCHED AS SAFETY GLAZED. GLAZING AT NORTH ENTRANCE DOOR YET TO BE RESOLVED.

Corrective Action Required:
4 MISC RESOLVE ANY FIRE DEPARTMENT ISSUES

Verify Final Inspection Status	John Borns	Temporary C of O	Thursday, October 10, 2013
---------------------------------------	------------	------------------	----------------------------