



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20130856, Building Permit - Residential
Address: 200 SW JEFFERSON ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Mechanical Inspection - Residential	John Borns	Failed	Friday, October 11, 2013

Corrective Action Required

1 MISC

NEC 330.30: NON-METALLIC ELECTRICAL WHIP NOT SECURED TO WALL WITHIN 12" OF ENTRY TO A/C CONDENSER DISCONNECT ENCLOSURE. SHEATH IS DETACHED FROM CONNECTOR.

Comments: CALL FOR RE-INSPECTION WHEN READY.