



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132033, Building Permit - Commercial
Address: 400 SW LONGVIEW BLVD, Unit:160, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mark Harding	Failed	Friday, October 11, 2013

Corrective Action Required

1	MISC	1. PROVIDE MEDICAL GRADE MC IN ALL ROOMS.
---	------	---

Comments: