



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130393, Building Permit - Commercial
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, October 17, 2013

Partial Correction
1 MISC

FASTENER PATTERN ON SW1 SHEAR WALL SHEATHING
APPROVED.

Hood/Duct Inspection	John Borns	Partial	Thursday, October 17, 2013
---------------------------------	------------	---------	----------------------------

Partial Correction
1 MISC

IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION &
INSTALLATION: LIGHT TEST OF SHOP WELDS APPROVED; **LIGHT
TEST OF FIELD WELDS APPROVED.**

G.C. TO WITNESS INSTALLATION OF 1ST LAYER OF WRAP. 2ND
WRAP SUBJECT TO APPROVAL AT OR BEFORE ABOVE-CEILING
INSPECTION.

Corrective Action Required
2 MISC

IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD
PERFORMANCE TEST: NEBBS-CERTIFIED REPORT REQUIRED
TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS
OPERATIONAL AND BEFORE COMMERCIAL USE; SMOKE
CAPTURE TEST TO BE WITNESSED BY INSPECTOR BEFORE
ANY OCCUPANCY IS APPROVED.

Comments: