



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O. BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20131231, Building Permit - Commercial  
Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Friday, October 18, 2013

Corrective Action Required  
1 MISC

UNDERSLAB/GROUND ELECTRICAL OK BELOW:  
-SERVICE CONDUITS TO MDP AND SUBPANEL  
-SECONDARY TO SERVICE EQUIPMENT  
-CIRCUIT TO SUMP PUMP  
-CIRCUITS TO ALL LIGHT POLES

LIGHT POLE PIERS: 1 @ NORTH, 3 @SOUTH, ALL PIERS ALONG  
THE BACK CURB

**Comments:**