

PUBLIC WORKS ENGINEERING DIVISION

Punch List

| Date: Tuesday, October 22 | 2013 |
|---|---|
| То: | |
| | antial Completion for: ructure Permit - Commercial, Development-Complete |
| Certificate of Substantial this letter. The develope accordance with the City complete all items will res Acceptance is issued. PUNCH LIST CORRECTION inner loop fire line need to | n was completed for this project. It has been determined by Public Works that a ampletion can be released. The following items were incomplete as of the date of contractors and engineers have ninety (90) days to complete these deficiencies in of Lee's Summit's, Design and Construction Manual, Ordinance 5813. Failure to t in a freeze of building permits until all items are corrected and a Certificate of Final Need certification that the backflow device is funcional, The fire hydrants on the be painted as private, vegitation/sod needs to be established on bare groung in the east side of the project needs to be repaired. |
| , Developer (Signature & Date) | Bob Burns, Public Works Inspector (Signature & Date) |
| Original: Public Works Insp | ctions File |
| Copy: | |
| Developer | Public Works Development Engineering Manager |
| Contractor | |
| Design Engineer / Architect | |