



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131231, Building Permit - Commercial
Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Tuesday, October 22, 2013

Partial Correction
1 MISC

UNDERSLAB/GROUND ELECTRICAL OK BELOW:
-SERVICE CONDUITS TO MDP AND SUBPANEL
-SECONDARY TO SERVICE EQUIPMENT
-CIRCUIT TO SUMP PUMP
-CIRCUITS TO ALL LIGHT POLES

LIGHT POLE PIERS: 1 @ NORTH, 3 @SOUTH, ALL PIERS ALONG THE BACK CURB; **4 WITHIN 25' OF INDEPENDENCE AVE @ W END OF MAIN PARKING AREA + ONE @ NE AND ONE @ N OF MAIN PARKING AREA;**

Comments: