



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130446, Building Permit - Commercial
Address: 110 NE SAINT LUKES BLVD, Unit:520, LEES SUMMIT, MO 64086
110 NE SAINT LUKES BLVD, Unit:500, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, October 23, 2013

Partial Correction

1 MISC

STAIR TOWER FOR BLDG F EGRESS AT 5AS05 APPROVED FOR USE.

Corrective Action Required

2 MISC

IMC TABLE 403.3 FOOTNOTES "b" & "i" MECHANICAL EXHAUST SYSTEM FOR NAIL STATIONS REQUIRED LOCAL AT SOURCE OF FUMES AND DUST. SEE AT SPACE 5F102

Partial Correction

3 MISC

MEDICAL ONCOLOGY AREA INCLUDING 5F100/101/102 OK TO SET UP FOR OPERATION EXCEPT MANICURE STATION IN SPACE 5F102.

Comments: