



---

**PUBLIC WORKS ENGINEERING DIVISION**

**Punch List**


**Date:** Tuesday, October 22, 2013


**To:**

**Re: Certificate of Substantial Completion for:**  
Public Works Infrastructure Permit - Commercial, Development-Complete  
PRPWFC20130938

A comprehensive inspection was completed for this project. It has been determined by Public Works that a Certificate of Substantial Completion can be released. The following items were incomplete as of the date of this letter. The developer, contractors and engineers have ninety (90) days to complete these deficiencies in accordance with the City of Lee's Summit's, Design and Construction Manual, Ordinance 5813. Failure to complete all items will result in a freeze of building permits until all items are corrected and a Certificate of Final Acceptance is issued.

**PUNCH LIST CORRECTIONS:** Need certification that the backflow device is functional, The fire hydrants on the inner loop fire line need to be painted as private, vegetation/sod needs to be established on bare ground areas, the street crossing on the east side of the project needs to be repaired.

 10-23-13  
\_\_\_\_\_  
, Developer  
(Signature & Date)

 10-23-2013  
\_\_\_\_\_  
Bob Burns, Public Works Inspector  
(Signature & Date)

Original: Public Works Inspections File

Copy:

Developer

Public Works Development Engineering Manager

Contractor

Design Engineer / Architect