



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130393, Building Permit - Commercial  
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Khanh Nguyen	Partial	Monday, October 28, 2013

Partial Correction  
1 MISC

FASTENER PATTERN ON SW1 SHEAR WALL SHEATHING  
APROVED.

-TIE DOWN ANCHORS INSTALLED FOR SHEAR WALLS

<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Monday, October 28, 2013
---------------------------	--------------	---------	--------------------------

Partial Correction  
1 MISC

-FIREBLOCK ALL CONCEALED FURRED OUT WALL SPACES  
AROUND THE BUILDING PERIMETER AT CEILING LEVEL

\*\*OK TO ROCK WALLS EXCEPT AT THE CONCEALED FURRED  
OUT WALL SPACES

**Comments:**