

## CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

## **Inspection Summary**

Permit #: PRCOM20130305, Building Permit - Commercial Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Above Ceiling** John Borns Partial Friday, November 01, 2013 **Inspection** 

Partial Correction

1 MISC OVERHEAD WATER & DWV PIPING IN AREA "B": ONE UNISTRUT

HANGER TO BE INSTALLED; OK TO INSTALL PIPE INSULATION

WHEN READY

Rough Electrical John Borns Partial Friday, November 01, 2013

Inspection -Commercial

Partial Correction

1 MISC OK TO COVER WHEN READY ELECTRICAL CONDUIT AND BOXES

AT FLOATING ISOLATION SOUND MAT AT NEW MAIN LEVEL @

(A) TO (C) x (11) TO (13)

**Partial Correction** 

2 MISC NO ISSUES FOUND ON WIRING AND TERMINATIONS IN PANEL

MSB2

**Comments:**