



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130393, Building Permit - Commercial
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Partial	Tuesday, November 05, 2013

Partial Correction
1 MISC

FASTENER PATTERN ON SW1 SHEAR WALL SHEATHING
APROVED.

-TIE DOWN ANCHORS INSTALLED FOR SHEAR WALLS
- HOOD WALL CHANGED TO METAL STUDS OK TO COVER

Comments: