



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20130943, Building Permit - Residential
Address: 2050 SW COUNTY LINE RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Wednesday, November 06, 2013

Corrective Action Required
1 MISC

1. EGRESS LADDER
2. ADJUST WATER HEATER FLUE FOR POSITIVE FALL
3. PROVIDE REPORT ON SEPTIC SYSTEM FROM THE COUNTY

Comments: