



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20132445, Building Permit - Commercial  
Address: 1800 NE LANGSFORD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	Mike Copeland	Passed	Friday, November 08, 2013

**Comments: PULLED NEW FEEDERS FROM EXTERIOR POLE TO A NEW MAST AND LANDED NEW FEDDERS IN PANELS. RE-CONFIGURED GROUNDING ELECTRODE SYSTEM. WATER, BUILDING STEEL, AND DRIVEN ROD. SERVICE RELEASED TO KCP&L.**