



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132445, Building Permit - Commercial
Address: 1800 NE LANGSFORD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Mechanical Inspection - Commercial	Khanh Nguyen	Passed	Monday, November 11, 2013
Rough Electrical Inspection - Commercial	Khanh Nguyen	Passed	Monday, November 11, 2013

Comments:

CHECK ON FINAL: COMPLETE ELECTRICAL TO DAMPER AND INSTALL AUTO SHUT-OFF FOR AUX DRAIN PANS