



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131231, Building Permit - Commercial
Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Monday, November 11, 2013

Partial Correction
1 MISC

OK BELOW:
-PARAPET WALLS FRAMING

Partial Correction
2 MISC

OKAY TO COVER OFFICE AREA EXCLUDING TWO BATHROOMS.
INSTALL PLUMBING PROTECTION FOR DWV PIPING

Underground Electrical Inspection - Commercial	Khanh Nguyen	Passed	Monday, November 11, 2013
---	--------------	--------	---------------------------

Comments: