



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20130305, Building Permit - Commercial
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Partial	Tuesday, November 12, 2013

Partial Correction
1 MISC

OK TO COVER WHEN READY ELECTRICAL CONDUIT AND BOXES AT FLOATING ISOLATION SOUND MAT AT NEW MAIN LEVEL AT AREAS: (A) TO (C) x (11) TO (13); **THEATER SEATING AREA A205 INSPECTED BY MH WEEK OF 11/4/2013;**

Partial Correction
2 MISC

NO ISSUES FOUND ON WIRING AND TERMINATIONS IN PANEL MSB2

Comments: