



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20130393, Building Permit - Commercial  
Address: 194 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - Commercial</b>	John Borns	Passed	Friday, November 15, 2013

**Comments: OK TO COVER WHEN READY 6" PVC SANITARY SEWER SERVICE LINE FROM NEAR OUTLET OF GREASE INTERCEPTOR TO "T" CONNECTION AT SHOPPING CENTER MAIN.**