

Temporary Certificate of Occupancy

Permit #: PRRES20130710
Address: 1629 NE SHADOW VALLEY DR, LEES SUMMIT, MO 64064
Inspected On: Wednesday, November 20, 2013
Inspected By: Khanh Nguyen
Expiration Date: 12/20/2013 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Wednesday, November 20, 2013

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | MISC | -FINAL GRADE,SOD, AND SPLASHBLOCKS
-SEAL EXTERIOR: SEAL ABOVE METER AND ADJACENT ENCLOSURE,
SEAL GFCI AT A/C, SEAL LIGHTS
-COMPLETE GAS LINE TO WATER HEATER **GAS TEST REQUIRED |
|---|------|---|