



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20131453, Building Permit - Commercial
Address: 228 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Thursday, November 21, 2013

Partial Correction
1 MISC

FASTENER PATTERN EXTERIOR AT WALL SHEATHING FROM FF ELEVATION TO 9' ABOVE FF MEETS OR EXCEEDS INDUSTRY STANDARDS (NO SPEC FOUND ON DRAWINGS). **OK TO COVER TO 9' AFF WHEN READY.**

Comments: