



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20132456, Building Permit - Commercial
Address: 1195 NW VIEW HIGH DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Monday, November 25, 2013

Final Electrical Inspection - Commercial	John Borns	Failed	Monday, November 25, 2013
---	------------	--------	---------------------------

Corrective Action Required
1 MISC

UNDERGROUND ELECTRICAL CONDUIT WAS NOT REQUESTED
FOR INSPECTION AND IS NOT APPROVED FOR USE.

Comments: ELECTRICAL SERVICE RELEASED FOR TEMPORARY USE. USE BEYOND 4 MONTHS WILL REQUIRE FURTHER BONDING OF CABINETS.