

PLAN REVIEW CONDITIONS

November 26, 2013

AMERICAN EAGLE ELECTRICAL SERVICES LLC
909 NW 201ST RD
CLINTON, MO 6473 -

Permit No: PRCOM20132484
Project Title: HAWTHORN BANK SOLAR ARRAY
Project Address: 300 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081
Parcel Number: 62420090200000000
Location: TOWER PARK COMMERCIAL-PHASE 1---LOT 1
Type of Work: ALTERATION COMMERCIAL
Occupancy Group: BUSINESS
Description: ROOF MOUNTED PV SYSTEM - (SOLAR)

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

Fire Plan Review

Reviewed By: Jim Eden

Approved with Conditions

1. 102.7 Subjects not regulated by this code.

Where no applicable standards or requirements are set forth in this code, or are contained within other laws, codes, regulations, ordinances or bylaws adopted by the jurisdiction, compliance with applicable standards of the National Fire Protection Association or other nationally recognized fire safety standards, as approved, shall be deemed as prima facie evidence of compliance with the intent of this code. Nothing herein shall derogate from the authority of the fire code official to determine compliance with codes or standards for those activities or installations within the fire code official's jurisdiction or responsibility.

The currently adopted 2006 International Fire Code (IFC) does not address PV systems, but the 2012 IFC does and has been adopted and will take effect Jan. 1, 2014. The 2012 IFC is the reference document for this review.

2. 605.3.1 Labeling. Doors into electrical control panel

rooms shall be marked with a plainly visible and legible sign stating ELECTRICAL ROOM or similar approved wording. The disconnecting means for each service, feeder or branch circuit originating on a switchboard or panelboard shall be legibly and durably marked to indicate its purpose unless such purpose is clearly evident.

Verified at inspection.

_____ Approved to issue per the listed conditions.

_____ Do not issue per the listed conditions.

_____ Approved to construct foundation only per the listed conditions.

_____ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

_____	_____
Signature of Applicant	Date

_____	_____
Print Applicant Name	CompanyName

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.